



115 kV CE

1 CORE - CROSSLINKED POLYETHYLENE POWER CABLE



Construction

: Circular compact stranded annealed copper

: Semi-conductive tape with extruded Semi-

: Semi-conductive cross-linked polyethylene

6. Metallic screen : Copper wires with copper contact tape

7. Water blocking and : Non-conductive water blocking tape

Revision: 04, May 2020

Reference Standard



Classification

Application

	Conduct	tor	Thickness	Thickness	Diameter	Thickness	Area	Thickness	Overall	DC.	Capacitance	Current	Cable	Standard
Cross-	No.	Diameter	of	of	over	of	of	of	diameter	Conductor		rating	weight	length
sectional	of		conductor	insulation	insulation	insulation	metallic	sheath	(Excluding	resistance		direct	(Excluding	
area	wires		screen			screen	screen*		Rib)	at 20°C		burial in	Rib)	
												ground		
												at 30°C		
mm ²		mm	mm	mm	mm	mm	mm ²	mm	mm	Ω /km	μF/km	А	kg/km	m/drum
	(Min.)	(Approx.)	(Nominal)	(Nominal)	(Approx.)	(Nominal)		(Nominal)	(Approx.)	(Max.)	(Nominal)		(Approx.)	
400	53	23.39	1.5	16.0	59.4	1.5	120	3.5	78	0.0470	0.170	690	8,270	500
500	53	26.67	1.5	16.0	62.6	1.5	120	3.5	82	0.0366	0.187	785	9,500	500
630	53	30.22	1.5	16.0	66.2	1.5	120	3.5	85	0.0283	0.203	890	11,060	300
800	53	34.00	1.5	16.0	70.0	1.5	120	3.5	89	0.0221	0.219	1010	12,950	300


^{*} The area of metallic screen can be designed upon request by not less than 95 mm²





115 kV CE

1 CORE - CROSSLINKED POLYETHYLENE POWER CABLE



Construction

1. Conductor : Circular compact stranded annealed copper

2. Conductor screen : Semi-conductive tape with extruded Semi-

conductive cross-linked polyethylene compound

3. Insulation : Cross-linked polyethylene (XLPE) compound

Insulation screen : Semi-conductive cross-linked polyethylene

compound

5. Water blocking tape: Semi-conductive water blocking tape

6. Metallic screen : Copper wires with copper contact tape

7. Water blocking and : Non-conductive water blocking tape

Cushioning tape

8. Radial water barrier : Copolymer aluminium tape

9. Sheath : Black Polyethylene (PE) , (Optional : with RIB

Reference Standard

IFC 6084

TIS 2202



Classification

. 70 C

Maximam circuit voltage

. 140 147

Application

Preferably laid in substations, factories and urban area. The cable shall be suitable for use in ducts, trays and direct burial in ground, subjected to immerse in water all time.

Conductor	AC Resistance of	Inductance	Reactance	Impedance
cross-	conductor at 90 °C			
sectional				
area				
mm ²	Ω /km	mH/km	Ω /km	Ω /km
	(Approx.)	(Approx.)	(Approx.)	(Approx.)
400	0.0614	0.614	0.193	0.203
500	0.0486	0.598	0.188	0.194
630	0.0385	0.580	0.182	0.186
800	0.0312	0.566	0.178	0.181

^{*} The area of metallic screen can be designed upon request by not less than 95 mm²

om B 139